

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0900:116

Page 1 of 1

CATEGORY: Annunciators

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015
Contact: *Sean Titus (816) 229-3405 ext 281

DESIGN: Models 10-111H, 10-111V, 10-112, 10-113H, 10-113V and 10-114 graphic annunciators. Refer to listee's data sheets for additional detailed product description and operational considerations.

10-1878, -1879, -1880	Enclosure
10-1881, -1882, -1883	Enclosure
10-2085	Main Board
10-2984	LED Driver Board
10-3517	Switch Board
10-2255	RS-485 Module

RATING: 18-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as annunciators for use with listee's separately listed compatible fire alarm control units.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager